



Local Government Energy Audit Report

Conover Road Elementary School

October 15, 2020

Prepared for:

Colts Neck Township School District
76 Conover Road
Colts Neck, New Jersey 07722

Prepared by:

TRC
900 Route 9 North
Woodbridge, New Jersey 07095

Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information about financial incentives that may be available. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated installation costs on our experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from RS Means. Cost estimates include material and labor pricing associated with installation of primary recommended equipment only. Cost estimates do not include demolition or removal of hazardous waste. We encourage the owner of the facility to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on individual measures and conditions. TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state and federal requirements.

Copyright ©2020 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Table of Contents

1	Executive Summary.....	1
1.1	Planning Your Project	4
	Pick Your Installation Approach	4
	More Options from Around the State	6
2	Existing Conditions.....	7
2.1	Site Overview.....	7
2.2	Building Occupancy	7
2.3	Building Envelope	8
2.4	Lighting Systems.....	9
2.5	Air Handling Systems	11
	Unit Ventilators	11
	Packaged Units	12
	Split Type & Window Air Conditioners and Split Heat Pumps	13
	Air Handling Units	13
	Exhaust Fans.....	13
2.6	Heating Hot Water Systems	15
2.7	Domestic Hot Water	16
2.8	Food Service Equipment.....	17
2.9	Refrigeration.....	18
2.10	Plug Load and Vending Machines	18
2.11	Water-Using Systems	19
3	Energy Use and Costs	20
3.1	Electricity	22
3.2	Natural Gas.....	23
3.3	Benchmarking.....	24
	Tracking Your Energy Performance.....	25
4	Energy Conservation Measures	26
4.1	Lighting	29
	ECM 1: Install LED Fixtures	29
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	29
	ECM 3: Retrofit Fixtures with LED Lamps.....	30
	ECM 4: Install LED Exit Signs.....	30
4.2	Lighting Controls.....	30
	ECM 5: Install Occupancy Sensor Lighting Controls	30
	ECM 6: Install High/Low Lighting Controls	31
4.3	Variable Frequency Drives (VFD).....	31
	ECM 7: Install VFDs on Constant Volume (CV) Fans	31
	ECM 8: Install VFDs on Heating Water Pumps	32
	ECM 9: Install VFDs on Kitchen Hood Fan Motors	32

4.4	Electric Unitary HVAC	33
	ECM 10: Install High Efficiency Air Conditioning Units.....	33
4.5	Gas-Fired Heating	33
	ECM 11: Install High Efficiency Furnaces.....	33
4.6	HVAC Improvements	34
	ECM 12: Implement Demand Control Ventilation (DCV)	34
4.7	Domestic Water Heating	35
	ECM 13: Install Low-Flow DHW Devices.....	35
4.8	Food Service & Refrigeration Measures.....	35
	ECM 14: Replace Refrigeration Equipment	35
	ECM 15: Vending Machine Control	36
4.9	Custom Measures.....	36
	ECM 16: Installation of an Energy Management System	36
5	Energy Efficient Best Practices	38
	Energy Tracking with ENERGY STAR® Portfolio Manager®	38
	Window Treatments/Coverings	38
	Lighting Maintenance.....	38
	Lighting Controls	39
	Motor Maintenance	39
	Thermostat Schedules and Temperature Resets	39
	Economizer Maintenance	39
	AC System Evaporator/Condenser Coil Cleaning	39
	HVAC Filter Cleaning and Replacement	39
	Ductwork Maintenance.....	40
	Boiler Maintenance	40
	Water Heater Maintenance	41
	Plug Load Controls.....	41
	Computer Power Management Software	41
	Water Conservation	42
	Procurement Strategies	42
6	On-site Generation	43
6.1	Solar Photovoltaic	44
6.2	Combined Heat and Power	46
7	Project Funding and Incentives.....	47
7.1	SmartStart	48
7.2	Direct Install	49
7.3	Pay for Performance - Existing Buildings.....	50
7.4	Combined Heat and Power	51
7.5	Energy Savings Improvement Program	52
7.6	Transition Incentive (TI) Program.....	53
8	Energy Purchasing and Procurement Strategies	54
8.1	Retail Electric Supply Options.....	54
8.2	Retail Natural Gas Supply Options	54




Appendix A: Equipment Inventory & Recommendations	A-1
Appendix B: ENERGY STAR® Statement of Energy Performance.....	B-1
Appendix C: Glossary	C-1

1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPB) has sponsored this Local Government Energy Audit (LGEA) report for Conover Road Elementary School. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.

BUILDING PERFORMANCE REPORT



ENERGY STAR®
Benchmarking Score

30
(1-100 scale)

This building performs below the national average. This report contains suggestions about how to improve building performance and reduce energy costs.




Figure 1 - Energy Use by System


POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


Scenario 1: Full Package (all evaluated measures)

Installation Cost	\$399,670
Potential Rebates & Incentives ¹	\$63,700
Annual Cost Savings	\$33,925
Annual Energy Savings	Electricity: 244,899 kWh Natural Gas: 4,779 Therms
Greenhouse Gas Emission Savings	151 Tons
Simple Payback	9.9 Years
Site Energy Savings (all utilities)	21%



Scenario 2: Cost Effective Package²

Installation Cost	\$159,169
Potential Rebates & Incentives	\$50,840
Annual Cost Savings	\$27,452
Annual Energy Savings	Electricity: 217,754 kWh Natural Gas: 1,567 Therms
Greenhouse Gas Emission Savings	119 Tons
Simple Payback	3.9 Years
Site Energy Savings (all utilities)	14%



On-site Generation Potential

Photovoltaic	High
Combined Heat and Power	None

¹ Incentives are based on current SmartStart Prescriptive incentives. Other program incentives may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			127,443	47.1	-26	\$14,873	\$77,646	\$28,510	\$49,136	3.3	125,254
ECM 1	Install LED Fixtures	Yes	40,122	8.0	-8	\$4,684	\$25,355	\$3,300	\$22,055	4.7	39,447
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	2,577	0.9	-1	\$301	\$1,831	\$524	\$1,307	4.3	2,532
ECM 3	Retrofit Fixtures with LED Lamps	Yes	83,279	38.1	-17	\$9,718	\$49,084	\$24,686	\$24,398	2.5	81,836
ECM 4	Install LED Exit Signs	Yes	1,465	0.1	0	\$171	\$1,376	\$0	\$1,376	8.1	1,439
Lighting Control Measures			24,031	5.7	-5	\$2,804	\$25,138	\$11,500	\$13,638	4.9	23,611
ECM 5	Install Occupancy Sensor Lighting Controls	Yes	18,701	4.8	-4	\$2,182	\$17,938	\$4,400	\$13,538	6.2	18,374
ECM 6	Install High/Low Lighting Controls	Yes	5,330	1.0	-1	\$622	\$7,200	\$7,100	\$100	0.2	5,237
Variable Frequency Drive (VFD) Measures			76,594	17.9	78	\$9,890	\$117,142	\$17,700	\$99,442	10.1	86,286
ECM 7	Install VFDs on Constant Volume (CV) Fans	Yes	58,176	15.9	0	\$6,911	\$45,413	\$10,350	\$35,063	5.1	58,583
ECM 8	Install VFDs on Heating Water Pumps	No	15,730	1.9	0	\$1,869	\$68,718	\$7,200	\$61,518	32.9	15,840
ECM 9	Install VFDs on Kitchen Hood Fan Motors	Yes	2,688	0.0	78	\$1,110	\$3,010	\$150	\$2,860	2.6	11,863
Electric Unitary HVAC Measures			4,644	5.7	0	\$552	\$47,812	\$4,860	\$42,952	77.9	4,676
ECM 10	Install High Efficiency Air Conditioning Units	No	4,644	5.7	0	\$552	\$47,812	\$4,860	\$42,952	77.9	4,676
Gas Heating (HVAC/Process) Replacement			0	0.0	115	\$1,167	\$33,986	\$800	\$33,186	28.4	13,519
ECM 11	Install High Efficiency Furnaces	No	0	0.0	115	\$1,167	\$33,986	\$800	\$33,186	28.4	13,519
HVAC System Improvements			603	0.0	93	\$1,013	\$5,438	\$0	\$5,438	5.4	11,507
ECM 12	Implement Demand Control Ventilation (DCV)	Yes	603	0.0	93	\$1,013	\$5,438	\$0	\$5,438	5.4	11,507
Domestic Water Heating Upgrade			0	0.0	17	\$169	\$344	\$230	\$114	0.7	1,961
ECM 13	Install Low-Flow DHW Devices	Yes	0	0.0	17	\$169	\$344	\$230	\$114	0.7	1,961
Food Service & Refrigeration Measures			4,813	0.5	0	\$572	\$2,180	\$100	\$2,080	3.6	4,847
ECM 14	Replace Refrigeration Equipment	Yes	3,201	0.4	0	\$380	\$1,950	\$0	\$1,950	5.1	3,223
ECM 15	Vending Machine Control	Yes	1,612	0.2	0	\$191	\$230	\$100	\$130	0.7	1,623
Custom Measures			6,772	0.0	206	\$2,885	\$89,985	\$0	\$89,985	31.2	30,909
ECM 16	Installation of an Energy Management System	No	6,772	0.0	206	\$2,885	\$89,985	\$0	\$89,985	31.2	30,909
TOTALS (COST EFFECTIVE MEASURES)			217,754	69.4	157	\$27,452	\$159,169	\$50,840	\$108,329	3.9	237,624
TOTALS (ALL MEASURES)			244,899	77.0	478	\$33,925	\$399,670	\$63,700	\$335,971	9.9	302,569

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

New Jersey's Clean Energy Programs give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives before purchasing materials or starting installation.

The potential ECMs identified for this building likely qualify for multiple incentive and funding programs. Based on current program rules and requirements, your measures are likely to qualify for the following programs:

Energy Conservation Measure		SmartStart	Direct Install	Pay For Performance
ECM 1	Install LED Fixtures	X	X	X
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	X	X	X
ECM 3	Retrofit Fixtures with LED Lamps	X	X	X
ECM 4	Install LED Exit Signs		X	X
ECM 5	Install Occupancy Sensor Lighting Controls	X	X	X
ECM 6	Install High/Low Lighting Controls	X	X	X
ECM 7	Install VFDs on Constant Volume (CV) Fans	X	X	X
ECM 8	Install VFDs on Heating Water Pumps	X	X	X
ECM 9	Install VFDs on Kitchen Hood Fan Motors	X	X	X
ECM 10	Install High Efficiency Air Conditioning Units	X	X	X
ECM 11	Install High Efficiency Furnaces	X	X	X
ECM 12	Implement Demand Control Ventilation (DCV)		X	X
ECM 13	Install Low-Flow DHW Devices	X	X	X
ECM 14	Replace Refrigeration Equipment		X	X
ECM 15	Vending Machine Control	X	X	X
ECM 16	Installation of an Energy Management System			X

Figure 3 – Funding Options



New Jersey's Clean Energy Programs At-A-Glance

	SmartStart Flexibility to install at your own pace	Direct Install Turnkey installation	Pay for Performance Whole building upgrades
Who should use it?	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together. Average peak demand should be below 200 kW. Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time. Peak demand should be over 200 kW.
How does it work?	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
What are the Incentives?	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project. You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
How do I participate?	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your Energy Reduction Plan and set your energy savings targets.

Take the next step by visiting www.njcleanenergy.com for program details, applications, and to contact a qualified contractor.

Individual Measures with SmartStart

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation.

Turnkey Installation with Direct Install

The Direct Install program provides turnkey installation of multiple measures through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70 percent of the cost of selected measures. Direct Install contractors will assess and verify individual measure eligibility and, in most cases, they perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

Whole Building Approach with Pay for Performance

Pay for Performance can be a good option for medium to large sized facilities to achieve deep energy savings. Pay for Performance allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also use this program. Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures resulting in at least 15 percent energy savings, where lighting cannot make up the majority of the savings.

More Options from Around the State

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat & Power (CHP)

The CHP program provides incentives for combined heat and power (aka cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Conover Road Elementary School. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs. This report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

On June 24, 2020, TRC performed an energy audit at Conover Road Elementary School located in Colts Neck, New Jersey. TRC met with Thomas Giglio to review the facility operations and help focus our investigation on specific energy-using systems. Mr. Giglio was very helpful throughout the energy audit process and made sure TRC had all the necessary information.

Conover Road Elementary School is a one-story, 85,689 square foot building built in 1967 with subsequent additional construction in 1998. Spaces include classrooms, a gymnasium, a cafeteria, a media center, offices, corridors, a kitchen, locker rooms, two boiler rooms, and storage rooms.

The site is interested in a new energy management system (EMS) and is currently planning its scope and installation. The Board of Education plans to have the EMS installed by the end of summer, 2020.

2.2 Building Occupancy

The facility is occupied regular hours from September through June (school season is 10 months) and has reduced occupancy during July and August. The gymnasium is occupied on Sundays from 7:00 am until 3:00 pm. Typical weekday occupancy is approx. 65 staff and 275 students.

During summer (late June, July, and August), the gymnasium, cafeteria, and a few classrooms are occupied occasionally for extended school and recreational programs.

Building Name	Weekday/Weekend	Operating Schedule
Conover Road Elementary School (School Hours)	Weekday	7:00 AM - 4:00 PM
	Weekend	7:00 AM - 3:00 PM
	Summer	Varies
Conover Road Elementary School (Custodial Hours)	Weekday	7:00 AM - 11:00 PM
	Weekend	7:00 AM - 4:00 PM
	Summer	Varies

Figure 4 - Building Occupancy Schedule

2.3 Building Envelope

Building walls are concrete block over structural steel with a brick facade. The roof over the gymnasium and 1998 building section is flat and covered with white membrane. The roof on the remaining 1967 sections of the school is also flat and covered with grey membrane. According to facility staff, some roof sections are in poor condition.

Most of the windows are old and single glazed. Windows have aluminum frames. The glass-to-frame seals are in fair condition.

Exterior doors have aluminum frames with double pane glazing in the center and are in good condition with undamaged door seals.



Exterior wall classroom wing



Exterior wall



Roof with membrane finish



Classroom window

2.4 Lighting Systems

The primary interior lighting system uses 32-Watt linear fluorescent T8 lamps. There are also several compact fluorescent lamps (CFL), a few 40-Watt and 34-Watt T12 fixtures and a few incandescent bulbs, LED bulbs, 32-Watt U-shaped T8 fluorescent lamps, and 4-foot LED linear tubes. Gymnasium fixtures have manually controlled high bay high-output, 54-Watt linear fluorescent lamps, and there are some metal halide fixtures in the gymnasium and media center. Typically, T8 fluorescent lamps use electronic ballasts while T12 fluorescent lamps use magnetic ballasts.


Fixture types include 1- 2- 4-lamp, 4-foot long troffer, recessed, and surface mounted fixtures. There are also 2-foot fixtures with U-bend tube lamps. Most fixtures are in good condition.

Most of the exit signs are LED; however, there are a few exit signs with CFL lamps.

Although interior lighting levels were generally sufficient, and a considerable number of classrooms with 4-lamp 32-Watt T8 linear fluorescent fixtures had lighting levels beyond the recommended lighting level (30 - 50 foot-candles) and were over lit. Besides being visually uncomfortable, over lit spaces lead to excess energy consumption. When the school upgrades the lighting to LED, it is recommended that the school facility staff works with the contractor to ensure that lighting levels are not excessive.



2' x 4' T8 4-lamp fixture



2' x 4' T5 high output lamps in cafeteria



8-foot T12 lamps




Recessed can fixture with CFL

Lighting fixtures in 27 classrooms and the faculty break room were noted to be controlled by wall-mounted or ceiling-mounted occupancy sensors. All the remaining interior lighting is manually controlled by wall switches.



Metal halide fixtures in media center



4-foot LED tubes in boiler room



LED lamps in boiler room



2' x 2' U-shaped T8 lamp fixture

Exterior fixtures include pole-mounted LED fixtures, LED wall packs, bollard fixtures with LED lamps, recessed can fixtures with CFLs, and under canopy fixtures with CFL and LED lamps. There are also a few wall-mounted fixtures with metal halide lamps. All exterior fixtures are timer controlled.



Wall-mounted LED fixture



Exterior metal halide lamps



Canopy fixture with CFL



Bollard fixture with LED lamps

2.5 Air Handling Systems

Unit Ventilators

Unit ventilators are installed in 24 classrooms and in the faculty break room. They have supply fan motors and provide only space heating and ventilation. All unit ventilators are original to the building and are controlled by individual thermostats. We recommend installing new unit ventilators when a capital improvement project is undertaken.

Packaged Units

There are eight packaged rooftop units (RTUs) and three packaged terminal heat pumps (PTHP) that serve different areas. One of the RTUs is a make-up air unit as noted. The table below lists the areas served by these units and specifies whether they provide cooling or heating.

List of all packaged heating/cooling units			
Unit Type	Area Served	Heating/Cooling	Make
Make-up Air Unit	Classrooms (#13 to 23) and hallways	Heating only (gas-fired furnace)	Reznor
Packaged Rooftop Unit	Classrooms	Heating only (hot water coils)	McQuay
Packaged Rooftop Unit	Media center	Heating only (hot water coils)	McQuay
Packaged Rooftop Unit	Classrooms	Heating only (hot water coils)	McQuay
Packaged Rooftop Unit	Computer Room for Students	Heating (Furnace) and Cooling (Direct Expansion [DX])	—
Packaged Rooftop Unit	Cafetorium	Heating (hot water coils) and Cooling (DX)	Carrier
Packaged Rooftop Unit	Cafetorium	Heating (Hot water coils) and Cooling (DX)	Trane
Packaged Rooftop Unit	Band Room	Cooling only (DX)	Trane
Packaged Terminal Heat Pump x 3	Main Office	Heating and Cooling (both DX)	McQuay

Out of the eight RTUs, four RTUs provide cooling via DX coils (computer room, cafeteria, and band room), and their cooling capacities range between 5-ton and 15-ton. Their cooling EER values are between 10.0 and 11.0 and are controlled by thermostats.

Three RTUs provide heating only for the classrooms and media center. One RTU is a make-up air unit that provides space heating only for classrooms and hallways.

Three PTHP serve the main office. Each PTHP has 1-ton cooling capacity and a heating capacity of 10.8 MBh. Each PTHP unit also has supplemental electric resistance heating at 4 kW (13.6 MBh) capacity. The units are in fair condition.

All packaged units in the above table except the RTUs for the cafetorium are more than 20 years old and are beyond useful life.

Split Type & Window Air Conditioners and Split Heat Pumps

There are 19 window air conditioners (AC) installed in the classrooms (0.7-ton capacity), one split air-source heat pump (0.75-ton capacity), and five split system ACs, ranging from 1.5 to 10.5-ton in capacity. The SEER for the window ACs is 12.1; the SEER for the split air-source heat pump is 23.0, and the nameplate SEER values for the five split system ACs range between 10.7 and 13.0.

Rooms 11 & 12, nurse's office, conference room, and media center are served by the five split AC units.

The single split air-source heat pump mentioned above serves one main distribution frame room with a heating capacity of 12.0 MBh and heating COP of 4.8.

There is also one portable AC installed in a classroom. It has a cooling capacity of 0.75-ton and the SEER for this unit is 8.5.

The units beyond useful life include the split AC units serving rooms 11 & 12, the nurse's office, conference room, one of the two media center units, and the portable AC unit.

Air Handling Units

The gymnasium and spaces/rooms in it are served by an air handling unit (AHU) and a furnace for space heating. The AHU has a 15 hp supply fan and the gas-fired furnace has a heating capacity of approximately 1,500 MBh. There is no space cooling for the gymnasium.

Exhaust Fans

There are approximately 30 exhaust fans installed on the roof. The exhaust fans serve hallways, the kitchen cooking area, the dishwashing area, restrooms, the gymnasium, and boiler rooms. Fan motors range from 0.25 hp to 1 hp. The exhaust fans are in fair condition.



Packaged rooftop unit



Packaged rooftop unit



Split type AC outdoor unit



Split type heat pump outdoor unit



Gymnasium AHU and furnace



Window AC in classroom



Unit Ventilator



Packaged Terminal Heat Pump in main office

2.6 Heating Hot Water Systems


Two Smith 3,098 output MBh hot water boilers serve a majority of the building's heating load. The boilers are non-condensing type with efficiency of 80 percent. The boilers are configured in an automated lead-lag control scheme. The boilers are about 22 years old and are in fair condition.

Heating hot water is supplied throughout the building by a total of four 5 hp constant speed pumps. One set of two 5 hp pumps serves the 1998 section while the other set of pumps serves the original section of the building. The pumps operate in an automated lead-lag control scheme. The pumps serving the 1998 building section were replaced around mid-2020. The boilers and pumps provide hot water to unit ventilators and RTU hot water coils.

The hot water supply temperature remains between 160°F and 170°F during peak winter periods and is reduced based on increased outdoor air temperature.



Smith hot water boilers



5 hp hot water pumps



5 hp hot water pumps



Smith hot water boiler

2.7 Domestic Hot Water

Domestic hot water (DHW) for use in kitchen, restrooms, and other areas of the building is produced by one 100 gallon, 400 MBh gas-fired A.O Smith storage water heater. The water heater is non-condensing with a maximum efficiency of 80 percent. The water heater is in fair condition.

The domestic hot water pipes are insulated, and the insulation is in good condition.



Domestic hot water heater



DHW circulation pump

2.8 Food Service Equipment

The kitchen has a mix of gas and electric equipment that is used to prepare and store meals for students. Most of the cooking is done using the convection gas-fired ovens. Also, there is one electric cooker and one electric steamer.

A high temperature type dishwasher unit is also installed in the kitchen and it also has an electric booster water heater. The dishwasher is not ENERGY STAR® rated.



Gas-fired ovens



Electric steamer



Dishwasher



Electric cooker

2.9 Refrigeration

The kitchen has a stand-up refrigerator and a stand-up freezer with solid doors, a refrigerator chest and a freezer chest. All equipment is in good condition. The stand-up freezer is ENERGY STAR® rated.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.



Stand-up refrigerator



Stand-up freezer



Freezer chest



Refrigerator Chest

2.10 Plug Load and Vending Machines

The school is doing a great job managing their electrical plug loads. This report makes additional suggestions for ECMs in this area as well as energy efficient best practices.

There are approximately 350 desktop computer workstations and laptop computers throughout the facility. Other plug loads throughout the building include general café and office equipment. Café equipment includes heated/chilled serving tables in the kitchen, microwave ovens and toaster ovens, residential style refrigerators, coffee makers, and hot/cold water dispensers in the break room and nurse's office. Office and other equipment include printers, copiers, and a paper shredder. There are also typical classroom plug load equipment such as smart boards, projectors, televisions and fans.

There is one refrigerated beverage vending machine and one non-refrigerated snack vending machine in the faculty break room.



Microwave oven



Residential style refrigerator



Large printer/copier



Vending machines

2.11 Water-Using Systems

Faucet flow rate in most restrooms is at 2.5 gallons per minute (gpm), while in a few restrooms it is 0.5 gpm. Faucet flow rates in the kitchen, classrooms, and faculty break room are also at 2.5 gpm.



0.5 gpm faucet




2.5 gpm faucet

3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	550,308 kWh	\$65,373
Natural Gas	43,299 Therms	\$43,781
Total		\$109,154



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.





Figure 5 - Energy Balance

3.1 Electricity

JCP&L delivers electricity under rate class General Service Secondary 3 Phase, with electric production provided by East Coast Power & Gas, a third-party supplier.




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
11/8/18	29	44,200	162	\$956	\$5,633
12/8/18	30	39,800	168	\$989	\$5,174
1/10/19	33	60,800	184	\$1,093	\$6,780
2/8/19	29	62,200	200	\$1,193	\$7,112
3/11/19	31	56,400	194	\$1,155	\$6,405
4/9/19	29	50,800	183	\$1,087	\$5,822
5/9/19	30	44,600	163	\$962	\$5,266
6/10/19	32	41,400	169	\$1,055	\$4,924
7/10/19	30	37,200	156	\$969	\$4,579
8/8/19	29	36,600	114	\$687	\$4,262
9/10/19	33	33,400	145	\$895	\$4,164
10/9/19	29	41,400	179	\$1,040	\$5,072
Totals	364	548,800	200	\$12,082	\$65,194
Annual	365	550,308	200	\$12,115	\$65,373

Notes:

- Peak demand of 200 kW occurred in January '19.
- Average demand over the past 12 months was 168 kW.
- The average electric cost over the past 12 months was \$0.119/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.

3.2 Natural Gas

New Jersey Natural Gas delivers natural gas under rate class Monthly 057CNN2G, with natural gas supply provided by UGI Energy Services, a third-party supplier.



Gas Billing Data			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
11/26/18	33	5,804	\$5,100
12/27/18	31	7,177	\$6,157
1/25/19	29	7,561	\$8,020
2/26/19	32	8,871	\$8,471
3/27/19	29	6,715	\$6,001
4/26/19	30	3,508	\$3,409
5/28/19	32	2,162	\$2,316
6/26/19	29	147	\$760
7/29/19	33	115	\$730
8/27/19	29	103	\$720
9/25/19	29	132	\$714
10/25/19	30	1,123	\$1,503
Totals	366	43,418	\$43,901
Annual	365	43,299	\$43,781

Notes:

- The average gas cost for the past 12 months is \$1.011/therm, which is the blended rate used throughout the analysis.

3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) *Portfolio Manager*® software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR® benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.




Figure 6 - Energy Use Intensity Comparison³

At 72.4 kBTU/ft², this building's energy usage exceeds the national average of 60.1 kBTU/ft² for schools, meaning building performance is slightly below the national average

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. A number of factors can cause a building to vary from the "typical" energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

³ Based on all evaluated ECMs

Tracking Your Energy Performance

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager® regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager® account for your facility and we have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR® and Portfolio Manager®, visit their website⁴.

⁴ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify and evaluate potential energy efficiency improvements, provide information about the cost effectiveness of those improvements, and recognize potential financial incentives from NJBPU. Most energy conservation measures have received preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives are based on the current NJCEP prescriptive SmartStart program. A higher level of investigation may be necessary to support any SmartStart Custom, Pay for Performance, or Direct Install incentive applications. Some measures and proposed upgrades may be eligible for higher incentives than those shown below through other NJCEP programs described in a following section of this report.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see **Appendix A: Equipment Inventory & Recommendations**.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			127,443	47.1	-26	\$14,873	\$77,646	\$28,510	\$49,136	3.3	125,254
ECM 1	Install LED Fixtures	Yes	40,122	8.0	-8	\$4,684	\$25,355	\$3,300	\$22,055	4.7	39,447
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	2,577	0.9	-1	\$301	\$1,831	\$524	\$1,307	4.3	2,532
ECM 3	Retrofit Fixtures with LED Lamps	Yes	83,279	38.1	-17	\$9,718	\$49,084	\$24,686	\$24,398	2.5	81,836
ECM 4	Install LED Exit Signs	Yes	1,465	0.1	0	\$171	\$1,376	\$0	\$1,376	8.1	1,439
Lighting Control Measures			24,031	5.7	-5	\$2,804	\$25,138	\$11,500	\$13,638	4.9	23,611
ECM 5	Install Occupancy Sensor Lighting Controls	Yes	18,701	4.8	-4	\$2,182	\$17,938	\$4,400	\$13,538	6.2	18,374
ECM 6	Install High/Low Lighting Controls	Yes	5,330	1.0	-1	\$622	\$7,200	\$7,100	\$100	0.2	5,237
Variable Frequency Drive (VFD) Measures			76,594	17.9	78	\$9,890	\$117,142	\$17,700	\$99,442	10.1	86,286
ECM 7	Install VFDs on Constant Volume (CV) Fans	Yes	58,176	15.9	0	\$6,911	\$45,413	\$10,350	\$35,063	5.1	58,583
ECM 8	Install VFDs on Heating Water Pumps	No	15,730	1.9	0	\$1,869	\$68,718	\$7,200	\$61,518	32.9	15,840
ECM 9	Install VFDs on Kitchen Hood Fan Motors	Yes	2,688	0.0	78	\$1,110	\$3,010	\$150	\$2,860	2.6	11,863
Electric Unitary HVAC Measures			4,644	5.7	0	\$552	\$47,812	\$4,860	\$42,952	77.9	4,676
ECM 10	Install High Efficiency Air Conditioning Units	No	4,644	5.7	0	\$552	\$47,812	\$4,860	\$42,952	77.9	4,676
Gas Heating (HVAC/Process) Replacement			0	0.0	115	\$1,167	\$33,986	\$800	\$33,186	28.4	13,519
ECM 11	Install High Efficiency Furnaces	No	0	0.0	115	\$1,167	\$33,986	\$800	\$33,186	28.4	13,519
HVAC System Improvements			603	0.0	93	\$1,013	\$5,438	\$0	\$5,438	5.4	11,507
ECM 12	Implement Demand Control Ventilation (DCV)	Yes	603	0.0	93	\$1,013	\$5,438	\$0	\$5,438	5.4	11,507
Domestic Water Heating Upgrade			0	0.0	17	\$169	\$344	\$230	\$114	0.7	1,961
ECM 13	Install Low-Flow DHW Devices	Yes	0	0.0	17	\$169	\$344	\$230	\$114	0.7	1,961
Food Service & Refrigeration Measures			4,813	0.5	0	\$572	\$2,180	\$100	\$2,080	3.6	4,847
ECM 14	Replace Refrigeration Equipment	Yes	3,201	0.4	0	\$380	\$1,950	\$0	\$1,950	5.1	3,223
ECM 15	Vending Machine Control	Yes	1,612	0.2	0	\$191	\$230	\$100	\$130	0.7	1,623
Custom Measures			6,772	0.0	206	\$2,885	\$89,985	\$0	\$89,985	31.2	30,909
ECM 16	Installation of an Energy Management System	No	6,772	0.0	206	\$2,885	\$89,985	\$0	\$89,985	31.2	30,909
TOTALS			244,899	77.0	478	\$33,925	\$399,670	\$63,700	\$335,971	9.9	302,569

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		127,443	47.1	-26	\$14,873	\$77,646	\$28,510	\$49,136	3.3	125,254
ECM 1	Install LED Fixtures	40,122	8.0	-8	\$4,684	\$25,355	\$3,300	\$22,055	4.7	39,447
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	2,577	0.9	-1	\$301	\$1,831	\$524	\$1,307	4.3	2,532
ECM 3	Retrofit Fixtures with LED Lamps	83,279	38.1	-17	\$9,718	\$49,084	\$24,686	\$24,398	2.5	81,836
ECM 4	Install LED Exit Signs	1,465	0.1	0	\$171	\$1,376	\$0	\$1,376	8.1	1,439
Lighting Control Measures		24,031	5.7	-5	\$2,804	\$25,138	\$11,500	\$13,638	4.9	23,611
ECM 5	Install Occupancy Sensor Lighting Controls	18,701	4.8	-4	\$2,182	\$17,938	\$4,400	\$13,538	6.2	18,374
ECM 6	Install High/Low Lighting Controls	5,330	1.0	-1	\$622	\$7,200	\$7,100	\$100	0.2	5,237
Variable Frequency Drive (VFD) Measures		60,863	16.0	78	\$8,021	\$48,423	\$10,500	\$37,923	4.7	70,446
ECM 7	Install VFDs on Constant Volume (CV) Fans	58,176	15.9	0	\$6,911	\$45,413	\$10,350	\$35,063	5.1	58,583
ECM 9	Install VFDs on Kitchen Hood Fan Motors	2,688	0.0	78	\$1,110	\$3,010	\$150	\$2,860	2.6	11,863
HVAC System Improvements		603	0.0	93	\$1,013	\$5,438	\$0	\$5,438	5.4	11,507
ECM 12	Implement Demand Control Ventilation (DCV)	603	0.0	93	\$1,013	\$5,438	\$0	\$5,438	5.4	11,507
Domestic Water Heating Upgrade		0	0.0	17	\$169	\$344	\$230	\$114	0.7	1,961
ECM 13	Install Low-Flow DHW Devices	0	0.0	17	\$169	\$344	\$230	\$114	0.7	1,961
Food Service & Refrigeration Measures		4,813	0.5	0	\$572	\$2,180	\$100	\$2,080	3.6	4,847
ECM 14	Replace Refrigeration Equipment	3,201	0.4	0	\$380	\$1,950	\$0	\$1,950	5.1	3,223
ECM 15	Vending Machine Control	1,612	0.2	0	\$191	\$230	\$100	\$130	0.7	1,623
TOTALS		217,754	69.4	157	\$27,452	\$159,169	\$50,840	\$108,329	3.9	237,624

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 8 – Cost Effective ECMs

4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		127,443	47.1	-26	\$14,873	\$77,646	\$28,510	\$49,136	3.3	125,254
ECM 1	Install LED Fixtures	40,122	8.0	-8	\$4,684	\$25,355	\$3,300	\$22,055	4.7	39,447
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	2,577	0.9	-1	\$301	\$1,831	\$524	\$1,307	4.3	2,532
ECM 3	Retrofit Fixtures with LED Lamps	83,279	38.1	-17	\$9,718	\$49,084	\$24,686	\$24,398	2.5	81,836
ECM 4	Install LED Exit Signs	1,465	0.1	0	\$171	\$1,376	\$0	\$1,376	8.1	1,439

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources are proposed, we suggest converting all of a specific lighting type (e.g. linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Install LED Fixtures

Replace existing fixtures containing HID and fluorescent lamps with new LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

In some cases, HID fixtures can be retrofit with screw-based LED lamps. Replacing an existing HID fixture with a new LED fixture will generally provide better overall lighting optics; however, replacing the HID lamp with a LED screw-in lamp is typically a less expensive retrofit. We recommend you work with your lighting contractor to determine which retrofit solution is best suited to your needs and will be compatible with the existing fixture(s).

Maintenance savings may also be achieved since LED lamps last longer than other light sources and therefore do not need to be replaced as often.

Affected building areas: metal halide fixtures in the gymnasium and cafeteria and exterior fixtures with metal halide lamps.

ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Retrofit fluorescent fixtures by removing the fluorescent tubes and ballasts and replacing them with LED tubes and LED drivers (if necessary), which are designed to be used in retrofitted fluorescent fixtures.

The measure uses the existing fixture housing but replaces the electric components with more efficient lighting technology which use less power than other lighting technologies but provides equivalent lighting output. Maintenance savings may also be achieved since LED tubes last longer than fluorescent tubes and therefore do not need to be replaced as often.

Affected building areas: fluorescent fixtures with T12 tubes in boiler room, restrooms (near classroom 38), main office, and kitchen.

ECM 3: Retrofit Fixtures with LED Lamps

Replace fluorescent and incandescent lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies.

This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected building areas: all areas with fluorescent fixtures with T8 tubes, all fixtures with CFLs, and incandescent lamps.

ECM 4: Install LED Exit Signs

Replace compact fluorescent exit signs with LED exit signs. LED exit signs require virtually no maintenance and have a life expectancy of at least 20 years. This measure saves energy by installing LED fixtures, which use less power than other technologies with an equivalent lighting output. Maintenance savings and improved reliability may also be achieved, as the longer-lasting LED lamps will not need to be replaced as often as the existing lamps.

4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		24,031	5.7	-5	\$2,804	\$25,138	\$11,500	\$13,638	4.9	23,611
ECM 5	Install Occupancy Sensor Lighting Controls	18,701	4.8	-4	\$2,182	\$17,938	\$4,400	\$13,538	6.2	18,374
ECM 6	Install High/Low Lighting Controls	5,330	1.0	-1	\$622	\$7,200	\$7,100	\$100	0.2	5,237

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 5: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected building areas: offices, conference room, classrooms, gymnasium, media center, kitchen, computer room for students, restrooms, and storage rooms.

ECM 6: Install High/Low Lighting Controls

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be taken into account when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

Affected building areas: hallways and vestibules.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as an occupant approaches.

4.3 Variable Frequency Drives (VFD)

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		76,594	17.9	78	\$9,890	\$117,142	\$17,700	\$99,442	10.1	86,286
ECM 7	Install VFDs on Constant Volume (CV) Fans	58,176	15.9	0	\$6,911	\$45,413	\$10,350	\$35,063	5.1	58,583
ECM 8	Install VFDs on Heating Water Pumps	15,730	1.9	0	\$1,869	\$68,718	\$7,200	\$61,518	32.9	15,840
ECM 9	Install VFDs on Kitchen Hood Fan Motors	2,688	0.0	78	\$1,110	\$3,010	\$150	\$2,860	2.6	11,863

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.

ECM 7: Install VFDs on Constant Volume (CV) Fans

Install VFDs to control constant volume fan motor speeds. This converts a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor, if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature.

For air handlers with DX cooling systems, the minimum air flow across the cooling coil required to prevent the coil from freezing must be determined during the final project design. The control system programming should maintain the minimum air flow whenever the compressor is operating. Prior to implementation, verify minimum fan speed in cooling mode with the manufacturer. Note that savings will vary depending on the operating characteristics of each AHU.

Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

Affected air handlers: make-up air unit, three (heating only) McQuay RTUs, RTU for computer room for students, both cafeteria RTUs, band room RTU, and the AHU serving the gymnasium.

ECM 8: Install VFDs on Heating Water Pumps

We evaluated installing VFD to control heating water pumps. Two-way valves must serve the hot water coils and the hot water loop must have a differential pressure sensor installed. If three-way valves or a bypass leg are used in the hot water distribution they will need to be modified when this measure is implemented. As the hot water valves close, the differential pressure increases and the VFD modulates the pump speed to maintain a differential pressure setpoint.

Energy savings result from reducing pump motor speed (and power) as hot water valves close. The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

Affected pumps: all four heating hot water pumps.

ECM 9: Install VFDs on Kitchen Hood Fan Motors

Install VFDs and sensors to control the kitchen hood fan motors. The air flow of the hood is varied based on two key inputs: temperature and smoke/cooking fumes. The VFD controls the amount of exhaust (and kitchen make-up air) based on temperature—the lower the temperature the lower the flow. If the optic sensor is triggered by smoke or cooking fumes, the speed of the fan ramps up to 100 percent.

Energy savings result from reducing the hood fan speed (and power) when conditions allow for reduced air flow.

4.4 Electric Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Electric Unitary HVAC Measures		4,644	5.7	0	\$552	\$47,812	\$4,860	\$42,952	77.9	4,676
ECM 10	Install High Efficiency Air Conditioning Units	4,644	5.7	0	\$552	\$47,812	\$4,860	\$42,952	77.9	4,676

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high efficiency unit can be justified by the marginal savings from the improved efficiency. When the split type AC units for Rooms 11 &12, Nurse's office, conference room, computer room for students and the Carrier unit for media center are eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

ECM 10: Install High Efficiency Air Conditioning Units

We evaluated replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

Affected units: split type AC units for Rooms 11 &12, Nurse's office, conference room, computer room for students, and the Carrier unit for media center.

4.5 Gas-Fired Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Gas Heating (HVAC/Process) Replacement		0	0.0	115	\$1,167	\$33,986	\$800	\$33,186	28.4	13,519
ECM 11	Install High Efficiency Furnaces	0	0.0	115	\$1,167	\$33,986	\$800	\$33,186	28.4	13,519

ECM 11: Install High Efficiency Furnaces

We evaluated replacing standard efficiency furnaces with condensing furnaces. Improved combustion technology and heat exchanger design optimize heat recovery from the combustion gases which can significantly improve furnace efficiency. Savings result from improved system efficiency.

Note: these units produce acidic condensate that requires proper drainage.

Affected units: gas-fired furnace for gymnasium.

4.6 HVAC Improvements

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$) *	Estimated Net Cost (\$)	Simple Payback Period (yrs) **	CO ₂ e Emissions Reduction (lbs)
HVAC System Improvements		603	0.0	93	\$1,013	\$5,438	\$0	\$5,438	5.4	11,507
ECM 12	Implement Demand Control Ventilation (DCV)	603	0.0	93	\$1,013	\$5,438	\$0	\$5,438	5.4	11,507

ECM 12: Implement Demand Control Ventilation (DCV)

Demand control ventilation (DCV) monitors the indoor air's carbon dioxide (CO₂) content to measure room occupancy. This data is used to regulate the amount of outdoor air provided to the space for ventilation.

Standard ventilation systems often provide outside air based on a space's estimated maximum occupancy but not actual occupancy. During low occupancy periods, the space may then be over ventilated. This wastes energy through heating and cooling the excess outside air flow. DCV reduces unnecessary outdoor air intake by regulating ventilation based on actual occupancy levels. DCV is most suited for facilities where occupancy levels vary significantly from hour to hour and day to day.

Energy savings associated with DCV are based on hours of operation, space occupancy, outside air reduction, and other factors. Energy savings results from eliminating unnecessary ventilation and space conditioning.

Affected building areas: gymnasium and cafeteria.

4.7 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		0	0.0	17	\$169	\$344	\$230	\$114	0.7	1,961
ECM 13	Install Low-Flow DHW Devices	0	0.0	17	\$169	\$344	\$230	\$114	0.7	1,961

ECM 13: Install Low-Flow DHW Devices

Install low-flow devices to reduce overall hot water demand. The following low flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm
Faucet aerator (kitchen)	1.5 gpm
Showerhead	2.0 gpm
Pre-rinse spray valve (kitchen)	1.28 gpm

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing.

Additional cost savings may result from reduced water usage.

4.8 Food Service & Refrigeration Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Food Service & Refrigeration Measures		4,813	0.5	0	\$572	\$2,180	\$100	\$2,080	3.6	4,847
ECM 14	Replace Refrigeration Equipment	3,201	0.4	0	\$380	\$1,950	\$0	\$1,950	5.1	3,223
ECM 15	Vending Machine Control	1,612	0.2	0	\$191	\$230	\$100	\$130	0.7	1,623

ECM 14: Replace Refrigeration Equipment

Replace existing freezer chest with new ENERGY STAR® rated equipment. The energy savings associated with this measure come from reduced energy usage, due to more efficient technology, and reduced run times.

ECM 15: Vending Machine Control

Vending machines operate continuously, even during unoccupied hours. Install occupancy sensor controls to reduce energy use. These controls power down vending machines when the vending machine area has been vacant for some time, and they power up the machines at necessary regular intervals or when the surrounding area is occupied. Energy savings are dependent on the vending machine and activity level in the area surrounding the machines.

4.9 Custom Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Custom Measures		6,772	0.0	206	\$2,885	\$89,985	\$0	\$89,985	31.2	30,909
ECM 16	Installation of an Energy Management System	6,772	0.0	206	\$2,885	\$89,985	\$0	\$89,985	31.2	30,909

ECM 16: Installation of an Energy Management System

We understand that the Board of Education is interested in a new Energy Management System (EMS) for this site and is currently planning its scope and installation. We have provided an analysis of cost and savings potential which we believe to be conservative. Savings potential depends on current operations, the control capabilities of the new system, and how the system will be operated and maintained.

Most larger facilities have some type of energy management system (EMS) which provides for centralized, remote control and monitoring of HVAC equipment and sometimes lighting or other building systems. An EMS utilizes a system of temperature and pressure sensors that obtain feedback about field conditions and provide signals to control systems that adjust HVAC system operation for optimal functioning. Thirty years ago, most control systems were pneumatic systems driven by compressed air, with pneumatic thermostats and air driven actuators for valves and dampers. Pneumatic controls have largely been replaced by direct digital control (DDC) systems, but many pneumatic systems remain. Contemporary DDC systems afford tighter controls and enhanced monitoring and trending capabilities as compared to the older systems.

Often smaller facilities are not equipped with central controls. For many small sites, it has been less costly to install distributed local controls, such as programmable thermostats and timeclocks, rather than centralized DDC. Local controls do a reasonably good job of scheduling equipment and maintaining operating conditions by relying on controls integral to HVAC units, such as logic for compressor staging, to manage the equipment operating algorithms.

Even for smaller sites, inefficiencies arise when temperature sensors and thermostat schedules are not maintained, when there are separate systems for heating and cooling, and especially when equipment is added, or the facility is reconfigured or repurposed.

Based on our survey, it appears that the installation of an EMS at your site could increase the efficiency of your building HVAC system operation.

A controls upgrade would enable automated equipment “start” and “stop” times, temperature setpoints, lockouts and deadbands to be programmed remotely using a graphic interface. Controls can be configured to optimize ventilation and outside air intake by adjusting economizer position, damper function and fan speed. Existing chilled and hot water distribution system controls are typically “tied in”, including associated pumps and valves. Coordinated control of HVAC systems is dependent on a network of sensors and status points. A comprehensive building control system provides monitoring and control for all HVAC systems so operators can adjust system programming for optimal comfort and energy savings.

It is recommended that an HVAC engineer or contractor who specializes in energy management systems be contacted for a detailed evaluation and implementation costs. For the purposes of this report, the potential energy savings and measure costs were estimated based on industry standards and previous project experience. Further analysis should be conducted for the feasibility of this measure. This is not an investment grade analysis nor should be used as a basis for design and construction.

A high-level evaluation of potential savings and costs is provided for demonstration purposes only. It is a screening evaluation for the potential in installing an EMS. Based on industry standards and previous project experience, the potential energy savings may be up to 20 percent of existing HVAC energy use. The average cost for installing and EMS may be between \$2 and \$4 per square foot. Actual savings and costs will need to be outlined by the specific contractor engaged to implement the system. For the purposes of this report, we have conservatively estimated savings to be 3 percent of the HVAC energy consumption baseline.

5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs.

Operation and maintenance (O&M) plans enhance the operational efficiency of HVAC and other energy intensive systems and could save between 5 to 20 percent of the energy usage in your building without substantial capital investment. A successful plan includes your records of energy usage trends and costs, building equipment lists, current maintenance practices, planned capital upgrades, and incorporates your ideas for improved building operation. Your plan will address goals for energy-efficient operation, provide detail on how to reach the goals, and will outline procedures for measuring and reporting whether goals have been achieved.

You may already be doing some of these things— see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR® Portfolio Manager®



You've heard it before - you can't manage what you don't measure. ENERGY STAR® Portfolio Manager® is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions⁵. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Window Treatments/Coverings

Use high-reflectivity films or cover windows with shades or shutters to reduce solar heat gain and reduce the load on cooling and heating systems. Older, single pane windows and east or west-facing windows are especially prone to solar heat gain. In addition, use shades or shutters at night during cold weather to reduce heat loss.

Lighting Maintenance



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60 percent while still drawing full power.
- In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

⁵ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

Lighting Controls

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly. Adjust exterior lighting time clock controls seasonally as needed to match your lighting requirements.

Motor Maintenance

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Thermostat Schedules and Temperature Resets



Use thermostat setback temperatures and schedules to reduce heating and cooling energy use during periods of low or no occupancy. Thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Economizer Maintenance

Economizers can significantly reduce cooling system load. A malfunctioning economizer can increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air. Common economizer malfunctions include broken outdoor thermostat or enthalpy control, or dampers that are stuck or improperly adjusted.

Periodic inspection and maintenance will keep economizers working in sync with the heating and cooling system. This maintenance should be part of annual system maintenance, and it should include proper setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position.

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

HVAC Filter Cleaning and Replacement

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Ductwork Maintenance

Duct maintenance has two primary goals: keep the ducts clean to avoid air quality problems and seal leaks to save energy. Check for cleanliness, obstructions that block airflow, water damage, and leaks. Ducts should be inspected at least every two years.

The biggest symptoms of clogged air ducts are differing temperatures throughout the building and areas with limited airflow from supply registers. If a particular air duct is clogged, then air flow will only be cut off to some rooms in the building - not all of them. The reduced airflow will make it more difficult for those areas to reach the temperature setpoint which will cause the HVAC system to run longer to cool or heat that area properly. If you suspect clogged air ducts, ensure that all areas in front of supply registers are clear of items that may block or restrict air flow, and check for fire dampers or balancing dampers that have failed closed.

Duct leakage in commercial buildings can account for 5 percent to 25 percent of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building wasting conditioned air. Check ductwork for leakage. Eliminating duct leaks can improve ventilation system performance and reduce heating and cooling system operation.

Distribution system losses are dependent on air system temperature, the size of the distribution system, and the level of insulation of the ductwork. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is missing or worn, the system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely and efficiently. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the boiler tubes to improve heat transfer.


Water Heater Maintenance

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

Plug Load Controls



Reducing plug loads is a common way to decrease your electrical use. Limiting the energy use of plug loads can include increasing occupant awareness, removing under-used equipment, installing hardware controls, and using software controls. Consider enabling the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips⁶. Your local utility may offer incentives or rebates for this equipment.

Computer Power Management Software

Many computers consume power during nights, weekends, and holidays. Screen savers are commonly confused as a power management strategy. This contributes to avoidable, excessive electrical energy consumption. There are innovative power management software packages available that are designed to deliver significant energy saving and provide ongoing tracking measurements. A central power management platform helps enforce energy savings policies as well as identify and eliminate underutilized devices.

⁶ For additional information refer to “Assessing and Reducing Plug and Process Loads in Office Buildings” <http://www.nrel.gov/docs/fy13osti/54175.pdf>, or “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

Water Conservation



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense® ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense® website⁷ or download a copy of EPA's "WaterSense® at Work: Best Management Practices for Commercial and Institutional Facilities"⁸ to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR® or WaterSense® products where available.

⁷ <https://www.epa.gov/watersense>.

⁸ <https://www.epa.gov/watersense/watersense-work-0>.

6 ON-SITE GENERATION

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has high potential for installing a PV array.

The amount of free area, ease of installation (location), and the lack of shading elements contribute to the high potential. PV arrays located on the roof and parking lot may be feasible. If you are interested in pursuing the installation of PV, we recommend conducting a full feasibility study.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 9 - Photovoltaic Screening

Transition Incentive (TI) Program

The TI program is a bridge between the Legacy SREC Program and a to-be determined Successor Incentive Program. The program is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn TRECs (Transition Incentive Renewable Energy Certificates). The Transition Incentive is structured as a factorized renewable energy certificate. The factors allow the TI Program to provide differentiated financial incentives for different types of solar installation.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

Transition Incentive (TI) Program: <https://www.njcleanenergy.com/renewable-energy/programs/transition-incentive-program>

- **Basic Info on Solar PV in New Jersey:** www.njcleanenergy.com/whysolar.
- **New Jersey Solar Market FAQs:** www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs.
- **Approved Solar Installers in the New Jersey Market:** www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1.

6.2 Combined Heat and Power


Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. Low and infrequent thermal load is the most significant factor contributing to the lack of CHP potential.



Find a qualified firm that specializes in commercial CHP cost assessment and installation:
http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/

7 PROJECT FUNDING AND INCENTIVES

Ready to improve your building's performance? New Jersey's Clean Energy Programs can help. Pick the program that works best for you. Incentive programs that may apply to this facility are identified in the Executive Summary. This section provides an overview of currently available New Jersey's Clean Energy Programs.

	SmartStart <i>Flexibility to install at your own pace</i>	Direct Install <i>Turnkey installation</i>	Pay for Performance <i>Whole building upgrades</i>
Who should use it?	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together. Average peak demand should be below 200 kW. Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time. Peak demand should be over 200 kW.
How does it work?	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
What are the Incentives?	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project. You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
How do I participate?	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your Energy Reduction Plan and set your energy savings targets.
Take the next step by visiting www.njcleanenergy.com for program details, applications, and to contact a qualified contractor.			

7.1 SmartStart



SmartStart offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

SmartStart routinely adds, removes, or modifies incentives from year-to-year for various energy efficient equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers
Electric Unitary HVAC
Gas Cooling
Gas Heating
Gas Water Heating
Ground Source Heat Pumps
Lighting

Lighting Controls
Refrigeration Doors
Refrigeration Controls
Refrigerator/Freezer Motors
Food Service Equipment
Variable Frequency Drives

Incentives

The SmartStart Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type.

SmartStart Custom provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives. Custom incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings. Incentives are capped at 50 percent of the total installed incremental project cost, or a project cost buy down to a one-year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

Submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. You can work with your preferred contractor or use internal staff to install measures.

Visit www.njcleanenergy.com/SSB for a detailed program description, instructions for applying, and applications.

7.2 Direct Install



Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for

installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives, and controls.

Incentives

The program pays up to 70 percent of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

How to Participate

To participate in Direct Install, you will need to contact the participating contractor assigned to the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program, which will pass on to you in the form of reduced material and implementation costs. This means up to 70 percent of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30 percent of the cost is paid to the contractor by the customer.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

7.3 Pay for Performance - Existing Buildings



Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures that results in at least 15 percent source energy savings, and lighting cannot make up the majority of the savings.

P4P is a generally a good option for medium-to-large sized facilities looking to implement as many measures as possible under a single project to achieve deep energy savings. This program has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program.

Based on the site building and utility data provided, the facility meets the requirements of the current P4P program.

Incentives

Incentives are based on estimated and achieved energy savings ranging from \$0.18-\$0.22/kWh and \$1.80-\$2.50/therm, capped at the lesser of 50 percent total project cost, or \$1 million per electric account and \$1 million per natural gas account, per fiscal year, not to exceed \$2 million per project. An incentive of \$0.15/square foot is also available to offset the cost of developing the Energy Reduction Plan (see below) contingent on the project moving forward with measure installation.

How to Participate

Contact one of the pre-approved consultants and contractors ("Partners"). Under direct contract to you, they will help further evaluate the measures identified in this report through development of the energy reduction plan), assist you in implementing selected measures, and verify actual savings one year after the installation. Your Partner will also help you apply for incentives.

Approval of the final scope of work is required by the program prior to installation. Installation can be done by the contractor of your choice (some P4P Partners are also contractors) or by internal staff, but the Partner remains involved throughout construction to ensure compliance with the program requirements.

Detailed program descriptions, instructions for applying, applications and list of Partners can be found at: www.njcleanenergy.com/P4P.

7.4 Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65 percent (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

Incentives

Eligible Technologies	Size (Installed Rated Capacity) ¹	Incentive (\$/kW)	% of Total Cost Cap per Project ³	\$ Cap per Project ³
Powered by non-renewable or renewable fuel source ⁴	≤500 kW	\$2,000	30-40% ²	\$2 million
Gas Internal Combustion Engine	>500 kW - 1 MW	\$1,000		
Gas Combustion Turbine	> 1 MW - 3 MW	\$550	30%	\$3 million
Microturbine	>3 MW	\$350		
Fuel Cells with Heat Recovery				
Waste Heat to Power*	<1 MW	\$1,000	30%	\$2 million
	> 1MW	\$500		\$3 million

*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

How to Participate

You work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at: www.njcleanenergy.com/CHP.

7.5 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP.

ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.

7.6 Transition Incentive (TI) Program

The TI program is a bridge between the Legacy SREC Program and a to-be determined Successor Incentive Program. The program is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn TRECs (Transition Incentive Renewable Energy Certificates). The Transition Incentive is structured as a factorized renewable energy certificate. The factors allow the TI Program to provide differentiated financial incentives for different types of solar installations. NJBPU calculates the value of a Transition Renewable Energy Certificate (TREC) by multiplying the base compensation rate (\$152/MWh) by the project's assigned factor (i.e. $\$152 \times 0.85 = \$129.20/\text{MWh}$). The TREC factors are defined based on the chart below:

Project Type	Factor
Subsection (t): landfill, brownfield, areas of historic fill	1.00
Grid supply (Subsection (r)) rooftop	1.00
Net metered non-residential rooftop and carport	1.00
Community solar	0.85
Grid supply (Subsection (r)) ground mount	0.60
Net metered residential ground mount	0.60
Net metered residential rooftop and carport	0.60
Net metered non-residential ground mount	0.60

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number, which enables it to generate New Jersey TRECs.

Eligible projects may generate TRECs for 15 years following the commencement of commercial operations (also referred to as the "Transition Incentive Qualification Life"). After 15 years, projects may be eligible for a New Jersey Class I REC.

TRECs will be used by the identified compliance entities to satisfy a compliance obligation tied to a new Transition Incentive Renewable Portfolio Standard ("TI-RPS"), which will exist in parallel with, and completely separate from, the existing Solar RPS for Legacy SRECs. The TI-RPS is a carve-out of the current Class I RPS requirement. The creation of TRECs is based upon metered generation supplied to PJM-EIS General Attribute Tracking System ("GATS") by the owners of eligible facilities or their agents. GATS would create one TREC for each MWh of energy produced from a qualified facility.

TRECs will be purchased monthly by a TREC Administrator who will allocate the TRECs to the Load Serving Entities (BGS Providers and Third-Party Suppliers) annually based on their market share of retail electricity sold during the relevant Energy Year.

Solar projects help the State of New Jersey reach renewable energy goals outlined in the state's Energy Master Plan. The Transition Incentive Program online portal is now open to new applications effective May 1, 2020. There are instructions on "How and When to Transfer my SRP Registration to the Transition Incentive Program". If you are considering installing solar photovoltaics on your building, visit the following link for more information:

<https://www.njcleanenergy.com/renewable-energy/programs/transition-incentive-program>

8 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

8.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website⁹.

8.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate monthly. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website¹⁰.

⁹ www.state.nj.us/bpu/commercial/shopping.html.

¹⁰ www.state.nj.us/bpu/commercial/shopping.html.

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
ES Gym Furnace Room	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3, 5	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.2	152	0	\$18	\$453	\$170	15.9
ES Gymnasium / Gym storage room	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3, 5	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.2	244	0	\$28	\$562	\$160	14.1
ES Gymnasium / Gym storage mezzanine	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.2	216	0	\$25	\$329	\$180	5.9
ES Gymnasium / Gym main area	24	Metal Halide: (1) 400W Lamp	Wall Switch	S	458	3,640	1, 5	Fixture Replacement	Yes	24	LED - Fixtures: (1) 140W High-Bay Fixture	Occupancy Sensor	140	2,512	6.2	34,729	-7	\$4,052	\$23,294	\$1,680	5.3
ES Gymnasium / Gym	4	Exit Signs: Fluorescent	None		14	8,760	4	Fixture Replacement	No	4	LED Exit Signs: 2 W Lamp	None	6	8,760	0.0	308	0	\$36	\$290	\$0	8.1
ES Gymnasium / Gym office 1	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.1	203	0	\$24	\$189	\$40	6.3
ES Gymnasium / Boys bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	1,035	3, 5	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	714	0.0	48	0	\$6	\$153	\$20	23.8
ES Gymnasium / Boys bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	1,035	3, 5	Relamp	Yes	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	714	0.0	25	0	\$3	\$134	\$10	42.5
ES Gymnasium / Girls bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	1,035	3, 5	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	714	0.0	48	0	\$6	\$153	\$20	23.8
ES Gymnasium / Girls bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	1,035	3, 5	Relamp	Yes	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	714	0.0	25	0	\$3	\$134	\$10	42.5
ES Gymnasium / Between bathrooms	1	Compact Fluorescent: (1) 18W Plug-In Lamp	Wall Switch	S	18	1,035	3	Relamp	No	1	LED Lamps: (1) 13W Plug-In Lamp	Wall Switch	13	1,035	0.0	6	0	\$1	\$13	\$2	15.8
ES Gymnasium / Gym office 2	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,200	0.0	80	0	\$9	\$37	\$20	1.8
Classroom 7	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
ES boiler room / LED Fixture	2	LED - Fixtures: 15W Pendant LED Fixtures	Wall Switch	S	15	1,035		None	No	2	LED - Fixtures: 15W Pendant LED Fixtures	Wall Switch	15	1,035	0.0	0	0	\$0	\$0	\$0	0.0
ES boiler room	2	Linear Fluorescent - EST12: 4' T12 (34W) - 2L	Wall Switch	S	72	1,035	2	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,035	0.1	98	0	\$11	\$138	\$40	8.5
ES boiler room	1	Linear Fluorescent - EST12: 4' T12 (34W) - 2L	Wall Switch	S	72	1,035	2	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,035	0.0	49	0	\$6	\$69	\$20	8.5
ES boiler room	3	LED Lamps: (1) 9W A19 Screw-In Lamp	Wall Switch	S	9	1,035		None	No	3	LED Lamps: (1) 9W A19 Screw-In Lamp	Wall Switch	9	1,035	0.0	0	0	\$0	\$0	\$0	0.0
ES boiler room	1	Incandescent: (1) 65W BR40 Screw-In Lamp	Wall Switch	S	65	1,035	3	Relamp	No	1	LED Lamps: (1) 10W BR40 Screw-In Lamp	Wall Switch	10	1,035	0.0	63	0	\$7	\$26	\$6	2.7
Classroom 30	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 31	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.6	2,148	0	\$251	\$1,146	\$550	2.4
Classroom 31 / Small toilet in classroom	1	Compact Fluorescent: (2) 18W Plug-In Lamps	Wall Switch	S	36	660	3	Relamp	No	1	LED Lamps: (2) 13W Plug-In Lamps	Wall Switch	26	660	0.0	7	0	\$1	\$25	\$4	24.8
Classroom 30 / Small toilet in classroom	1	Compact Fluorescent: (2) 18W Plug-In Lamps	Wall Switch	S	36	660	3	Relamp	No	1	LED Lamps: (2) 13W Plug-In Lamps	Wall Switch	26	660	0.0	7	0	\$1	\$25	\$4	24.8
Classroom 32	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	O	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,609	0.7	1,805	0	\$211	\$918	\$240	3.2
Classroom 33	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9

Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis									
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 34	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 35 / Small toilet in classroom	2	Compact Fluorescent: (2) 18W Plug-In Lamps	Wall Switch	S	36	660	3, 5	Relamp	Yes	2	LED Lamps: (2) 13W Plug-In Lamps	Occupancy Sensor	26	455	0.0	26	0	\$3	\$166	\$8	51.6
Classroom 35	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.6	2,148	0	\$251	\$1,146	\$550	2.4
Classroom 36	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.1	203	0	\$24	\$189	\$40	6.3
Classroom 36	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.6	2,148	0	\$251	\$1,146	\$550	2.4
Classroom 37	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 38	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	8	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.4	1,432	0	\$167	\$854	\$390	2.8
Classroom 38 / Small corridor to classroom 38	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9
Classroom 38 / Table lamp	1	Incandescent: (1) 40W A19 Screw-In Lamp	Wall Switch	S	40	660	3	Relamp	No	1	LED Lamps: (1) 6W A19 Screw-In Lamp	Wall Switch	6	660	0.0	25	0	\$3	\$17	\$2	5.3
Restroom - Male (near class 38)	2	Linear Fluorescent - EST12: 4' T12 (34W) - 2L	Wall Switch	S	72	660	2, 5	Relamp & Reballast	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.1	75	0	\$9	\$254	\$40	24.2
Restroom - Male (near class 38)	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3, 5	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.0	30	0	\$4	\$37	\$20	4.6
Restroom - Female (cls 38)	1	Linear Fluorescent - EST12: 4' T12 (34W) - 2L	Wall Switch	S	72	660	2, 5	Relamp & Reballast	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.0	38	0	\$4	\$185	\$20	37.4
Restroom - Female (cls 38)	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3, 5	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.1	91	0	\$11	\$380	\$130	23.4
Copy Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.1	358	0	\$42	\$262	\$120	3.4
Nurse's office / Main area	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	2,200	3, 5	Relamp	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,518	0.2	762	0	\$89	\$544	\$220	3.6
Nurse's office / Main area	3	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	3	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,518	0.1	285	0	\$33	\$487	\$130	10.8
Nurse's office / Bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	660	3	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	660	0.0	13	0	\$1	\$18	\$10	5.6
Nurse's office / Exam room	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	1,035	3	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,035	0.0	56	0	\$7	\$55	\$30	3.8
Main Office / Main office- open area	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	2,200	5	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.1	261	0	\$30	\$270	\$70	6.6
Main Office / Break room	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	2,200	3, 5	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,518	0.1	305	0	\$36	\$226	\$100	3.5
Main Office / Conf room/ Special Ed room	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	2,200	3, 5	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,518	0.1	457	0	\$53	\$434	\$160	5.1
Main Office / Room 1	2	Linear Fluorescent - T12: 8' T12 (96W) - 2L	Wall Switch	S	192	2,332	2, 5	Relamp & Reballast	Yes	2	LED - Linear Tubes: (2) 8' Lamps	Occupancy Sensor	72	1,609	0.2	730	0	\$85	\$373	\$120	3.0
Main Office / Principal office	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	2,200	3, 5	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,518	0.2	610	0	\$71	\$489	\$190	4.2
Main Office / Small restroom	2	Linear Fluorescent - T12: 2' T12 (20W) - 2L	Wall Switch	S	50	2,200	2, 5	Relamp & Reballast	Yes	2	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,518	0.1	185	0	\$22	\$246	\$24	10.3
Cafetorium / Dining area	38	LED - Fixtures: 50W Cove LED Fixtures	Wall Switch	S	100	3,640	5	None	Yes	38	LED - Fixtures: 50W Cove LED Fixtures	Occupancy Sensor	100	2,512	0.8	4,717	-1	\$550	\$810	\$210	1.1

	Existing Conditions						Proposed Conditions									Energy Impact & Financial Analysis							
Location	Fixture Quantit y	Fixture Description	Control System	Light Level	Watts per Fixtur e	Annual Operatin g Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantit y	Fixture Description	Control System	Watts per Fixtur e	Annual Operatin g Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years		
Cafetorium / Stage lighting	5	Halogen Incandescent: (1) 150W BR40 Screw-In Lamp	Wall Switch	S	150	40	3	Relamp	No	5	LED Lamps: (1) 23W BR40 Screw-In Lamp	Wall Switch	23	40	0.5	28	0	\$3	\$129	\$30	30.2		
Cafetorium / Stage lighting	34	Incandescent: (1) 250W BR40 Screw-In Lamp	Wall Switch	S	250	40	3	Relamp	No	34	LED Lamps: (1) 38W BR40 Screw-In Lamp	Wall Switch	38	40	5.2	318	0	\$37	\$877	\$204	18.1		
Cafetorium / Stage area behind	32	Incandescent: (1) 250W BR40 Screw-In Lamp	Wall Switch	S	250	40	3	Relamp	No	32	LED Lamps: (1) 38W BR40 Screw-In Lamp	Wall Switch	38	40	4.9	299	0	\$35	\$825	\$192	18.1		
Cafetorium / Backstage	4	Compact Fluorescent: (1) 13W Plug-In Lamp	Wall Switch	S	13	40	3	Relamp	No	4	LED Lamps: (1) 10W Plug-In Lamp	Wall Switch	10	40	0.0	1	0	\$0	\$50	\$8	681.7		
Kitchen / Kitchen main area	15	Linear Fluorescent - EST12: 4' T12 (34W) - 2L	Wall Switch	S	72	2,200	2, 5	Relamp & Reballast	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.6	1,887	0	\$220	\$1,302	\$370	4.2		
Kitchen / Dishwasher area	1	Linear Fluorescent - T8: 8' T8 (59W) - 2L	Wall Switch	S	110	2,200	3, 5	Relamp	Yes	1	LED - Linear Tubes: (2) 8' Lamps	Occupancy Sensor	72	1,518	0.0	146	0	\$17	\$205	\$80	7.3		
Classroom 3	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9		
Storage room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3, 5	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.1	61	0	\$7	\$189	\$40	20.9		
Storage/ MDF room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9		
IT admin room(room 5)	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	2,200	3, 5	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,518	0.1	457	0	\$53	\$434	\$160	5.1		
Classroom 5	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	O	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,609	0.7	1,805	0	\$211	\$918	\$240	3.2		
Restroom - Female	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	660	3, 5	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	455	0.1	91	0	\$11	\$226	\$60	15.5		
Classroom 6	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9		
Classroom 8	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9		
Media center / Main area	11	Metal Halide: (1) 400W Lamp	Wall Switch	S	458	2,200	1, 5	Fixture Replacement	Yes	11	LED - Fixtures: Low-Bay	Occupancy Sensor	140	1,518	2.9	9,620	-2	\$1,123	\$7,420	\$3,440	3.5		
Media center / Main area	24	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	24	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.7	2,439	-1	\$285	\$1,416	\$620	2.8		
Media center / Main area	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.2	813	0	\$95	\$562	\$230	3.5		
Media center / Main area	10	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	1,035	3, 5	Relamp	Yes	10	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	714	0.5	842	0	\$98	\$1,000	\$470	5.4		
Media center / IDF room	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	1,035	3	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	1,035	0.0	64	0	\$7	\$73	\$40	4.4		
Media center / Room 1	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	1,035	3, 5	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	714	0.1	168	0	\$20	\$262	\$120	7.2		
Media center / Room 2	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	1,035	3, 5	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	714	0.2	253	0	\$29	\$489	\$190	10.1		
Media center / Small storage room	1	Compact Fluorescent: (1) 13W Plug-In Lamp	Wall Switch	S	13	660	3	Relamp	No	1	LED Lamps: (1) 10W Plug-In Lamp	Wall Switch	10	660	0.0	2	0	\$0	\$13	\$2	41.3		
Classroom 41	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	8	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.3	793	0	\$93	\$584	\$320	2.9		
Classroom 42	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9		
Classroom 42	3	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	S	22	2,200	3	Relamp	No	3	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	2,200	0.0	98	0	\$11	\$49	\$18	2.7		

Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis									
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 13	14	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	14	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.6	1,388	0	\$162	\$1,022	\$560	2.9
Classroom 13 / Storage room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9
Classroom 13 / Bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9
Classroom 14	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 17	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 15	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	O	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,609	0.7	1,805	0	\$211	\$918	\$240	3.2
Classroom 16	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 18	9	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.5	1,611	0	\$188	\$927	\$430	2.6
Classroom 19	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.6	2,148	0	\$251	\$1,146	\$550	2.4
Classroom 29	1	Compact Fluorescent: (2) 18W Plug-In Lamps	Wall Switch	S	36	2,200	3	Relamp	No	1	LED Lamps: (2) 13W Plug-In Lamps	Wall Switch	26	2,200	0.0	24	0	\$3	\$25	\$4	7.4
Classroom 29	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 28	1	Compact Fluorescent: (2) 18W Plug-In Lamps	Wall Switch	S	36	2,200	3	Relamp	No	1	LED Lamps: (2) 13W Plug-In Lamps	Wall Switch	26	2,200	0.0	24	0	\$3	\$25	\$4	7.4
Classroom 28	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 27	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	8	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.4	1,432	0	\$167	\$854	\$390	2.8
Faculty break room	16	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	16	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.6	1,586	0	\$185	\$1,168	\$640	2.9
Faculty break room / Storage room	1	Compact Fluorescent: (1) 18W Plug-In Lamp	Wall Switch	S	18	660	3	Relamp	No	1	LED Lamps: (1) 13W Plug-In Lamp	Wall Switch	13	660	0.0	4	0	\$0	\$13	\$2	24.8
Classroom 25	15	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	15	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.6	1,487	0	\$173	\$1,095	\$600	2.9
Classroom 25	2	Compact Fluorescent: (2) 18W Plug-In Lamps	Wall Switch	S	36	2,200	3, 5	Relamp	Yes	2	LED Lamps: (2) 13W Plug-In Lamps	Occupancy Sensor	26	1,518	0.0	87	0	\$10	\$166	\$8	15.5
Classroom 10	2	Compact Fluorescent: (2) 18W Plug-In Lamps	Wall Switch	S	36	2,200	3, 5	Relamp	Yes	2	LED Lamps: (2) 13W Plug-In Lamps	Occupancy Sensor	26	1,518	0.0	87	0	\$10	\$166	\$8	15.5
Classroom 10	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.3	1,074	0	\$125	\$708	\$310	3.2
Classroom 24	16	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	16	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.6	1,586	0	\$185	\$1,168	\$640	2.9
Classroom 24 / Bathroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3, 5	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.1	61	0	\$7	\$189	\$40	20.9
Classroom 24 / Storage room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3, 5	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	455	0.1	61	0	\$7	\$189	\$40	20.9
Copy room 11	5	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	5	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.3	895	0	\$104	\$635	\$270	3.5
Computer Lab 9	26	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	26	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.8	2,642	-1	\$308	\$1,489	\$660	2.7

Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis									
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 8	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Exterior Lighting	21	LED - Fixtures: 9W Bollard LED Fixtures	Timeclock	S	9	2,044		None	No	21	LED - Fixtures: 9W Bollard LED Fixtures	Timeclock	9	2,044	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Lighting	6	LED Lamps: (1) 84W High Output A Screw-In Lamp	Timeclock	S	84	2,044		None	No	6	LED Lamps: (1) 84W High Output A Screw-In Lamp	Timeclock	84	2,044	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Lighting	15	Compact Fluorescent: (2) 26W Plug-In Lamps	Timeclock	S	52	2,044	3	Relamp	No	15	LED Lamps: (2) 18.5W Plug-In Lamps	Timeclock	37	2,044	0.0	460	0	\$55	\$375	\$60	5.8
Exterior Lighting	6	Metal Halide: (1) 100W Lamp	Timeclock	S	128	2,044	1	Fixture Replacement	No	6	LED - Fixtures: 40W Outdoor Wall-Mounted Area Fixture	Timeclock	38	2,044	0.0	1,099	0	\$131	\$461	\$0	3.5
Exterior Lighting	16	LED - Fixtures: 30W Wall Pack LED Fixtures	Timeclock	S	30	2,044		None	No	16	LED - Fixtures: 30W Wall Pack LED Fixtures	Timeclock	30	2,044	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Lighting	6	Compact Fluorescent: (1) 26W Plug-In Lamp	Timeclock	S	26	2,044	3	Relamp	No	6	LED Lamps: (1) 19W Plug-In Lamp	Timeclock	19	2,044	0.0	86	0	\$10	\$75	\$12	6.2
Exterior Lighting	40	LED - Fixtures: 25W Pole Light LED Fixtures	Timeclock	S	25	2,044		None	No	40	LED - Fixtures: 25W Pole Light LED Fixtures	Timeclock	25	2,044	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 20	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.6	2,148	0	\$251	\$1,146	\$550	2.4
Classroom 23	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.6	2,148	0	\$251	\$1,146	\$550	2.4
Locked Room 1	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	660	3, 5	Relamp	Yes	2	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	455	0.0	31	0	\$4	\$181	\$24	43.6
Locked Room 2	3	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	660	5	None	Yes	3	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	455	0.0	10	0	\$1	\$116	\$0	101.5
Locked Room 1	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	660		None	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	660	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 21	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.1	406	0	\$47	\$416	\$150	5.6
Classroom 22	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	2,200	3, 5	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,518	0.2	716	0	\$84	\$562	\$230	4.0
Locked Room 3	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9
Locked Room 4	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9
Locked Room 5	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9
Men's Restroom	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.2	508	0	\$59	\$453	\$170	4.8
Women's Restroom	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,200	3, 5	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,518	0.2	508	0	\$59	\$453	\$170	4.8
Hallway water fountain	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	3,640	3, 6	Relamp	Yes	1	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	2,512	0.0	85	0	\$10	\$33	\$12	2.1
Hallway water fountain	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	3,640	3, 6	Relamp	Yes	1	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	2,512	0.0	85	0	\$10	\$33	\$12	2.1
IDF Room 4	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9
Near IDF Room 4	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	660	3	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	660	0.0	24	0	\$3	\$37	\$20	5.9
Classroom 43	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	O	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,609	0.7	1,805	0	\$211	\$918	\$240	3.2

Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis									
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 43	3	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	S	22	660	3	Relamp	No	3	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	660	0.0	29	0	\$3	\$49	\$18	9.0
Classroom 44	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 44	3	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	S	22	660	3	Relamp	No	3	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	660	0.0	29	0	\$3	\$49	\$18	9.0
Classroom 45	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 45	3	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	S	22	660	3	Relamp	No	3	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	660	0.0	29	0	\$3	\$49	\$18	9.0
Classroom 46	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 46	3	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	S	22	660	3	Relamp	No	3	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	660	0.0	29	0	\$3	\$49	\$18	9.0
Classroom 47	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	1,609	3	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,609	0.5	1,189	0	\$139	\$876	\$480	2.9
Classroom 47	3	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	S	22	660	3	Relamp	No	3	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	660	0.0	29	0	\$3	\$49	\$18	9.0
Vestibule main entrance	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	3,640	3, 6	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	2,512	0.1	592	0	\$69	\$371	\$220	2.2
Hallway 1	32	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	32	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	1.0	5,380	-1	\$628	\$2,518	\$1,990	0.8
Hallway 2	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.2	1,177	0	\$137	\$706	\$590	0.8
Hallway 3	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.2	1,177	0	\$137	\$706	\$590	0.8
Hallway 4	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.2	1,177	0	\$137	\$706	\$590	0.8
Hallway 5	30	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	30	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.9	5,044	-1	\$589	\$2,445	\$1,950	0.8
Hallway 6	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.2	1,345	0	\$157	\$742	\$610	0.8
Hallway 7	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.4	2,354	0	\$275	\$1,186	\$955	0.8
Hallway 8	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.2	1,177	0	\$137	\$706	\$590	0.8
Hallway 9	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.3	1,681	0	\$196	\$815	\$650	0.8
Hallway 10	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.3	1,513	0	\$177	\$779	\$630	0.8
Hallway 11	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,640	3, 6	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,512	0.1	504	0	\$59	\$335	\$270	1.1
Hallway 1	2	Exit Signs: Fluorescent	None		14	8,760	4	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.0	154	0	\$18	\$145	\$0	8.1
Hallway 2	5	Exit Signs: Fluorescent	None		14	8,760	4	Fixture Replacement	No	5	LED Exit Signs: 2 W Lamp	None	6	8,760	0.0	385	0	\$45	\$362	\$0	8.1
Hallway 3	2	Exit Signs: Fluorescent	None		14	8,760	4	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.0	154	0	\$18	\$145	\$0	8.1
Hallway 4	3	Exit Signs: Fluorescent	None		14	8,760	4	Fixture Replacement	No	3	LED Exit Signs: 2 W Lamp	None	6	8,760	0.0	231	0	\$27	\$217	\$0	8.1

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Hallway 7	3	Exit Signs: Fluorescent	None		14	8,760	4	Fixture Replacement	No	3	LED Exit Signs: 2 W Lamp	None	6	8,760	0.0	231	0	\$27	\$217	\$0	8.1
Hallway 5	1	Compact Fluorescent: (2) 26W Plug-In Lamps	Wall Switch	S	52	3,640	3, 6	Relamp	Yes	1	LED Lamps: (2) 18.5W Plug-In Lamps	High/Low Control	37	2,512	0.0	106	0	\$12	\$25	\$4	1.7
Hallway 6	1	Compact Fluorescent: (2) 26W Plug-In Lamps	Wall Switch	S	52	3,640	3, 6	Relamp	Yes	1	LED Lamps: (2) 18.5W Plug-In Lamps	High/Low Control	37	2,512	0.0	106	0	\$12	\$25	\$4	1.7
Hallway 7	4	Compact Fluorescent: (2) 32W Plug-In Lamp	Wall Switch	S	64	3,640	3, 6	Relamp	Yes	4	LED Lamps: (2) 23W Biax Lamps	High/Low Control	46	2,512	0.1	517	0	\$60	\$441	\$257	3.1

Motor Inventory & Recommendations

		Existing Conditions							Proposed Conditions					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Classrooms + Hallways	1	Supply Fan	5.0	85.5%	No	W	2,873	7	No	89.5%	Yes	1	1.5	5,078	0	\$603	\$4,076	\$1,800	3.8
Roof	RTU 1	1	Supply Fan	10.0	87.2%	No	W	2,873	7	No	91.7%	Yes	1	3.1	10,031	0	\$1,192	\$5,152	\$2,200	2.5
Roof	RTU 1	1	Return Fan	3.0	86.5%	No	W	2,873	7	No	89.5%	Yes	1	0.9	2,956	0	\$351	\$3,884	\$400	9.9
Roof	RTU 2	1	Supply Fan	5.0	87.5%	No	W	2,873	7	No	89.5%	Yes	1	1.5	4,778	0	\$568	\$4,076	\$1,800	4.0
Roof	RTU 2	1	Return Fan	3.0	86.5%	No	W	2,873	7	No	89.5%	Yes	1	0.9	2,956	0	\$351	\$3,884	\$400	9.9
Roof	RTU 3	1	Supply Fan	1.0	77.0%	No	W	2,873	7	No	85.5%	Yes	1	0.3	1,231	0	\$146	\$3,010	\$150	19.6
Roof	Computer room for students	1	Supply Fan	2.0	84.0%	No	W	4,597	7	No	86.5%	Yes	1	0.6	3,221	0	\$383	\$3,261	\$200	8.0
Roof	Cafeteria unit 1	1	Supply Fan	3.0	86.5%	No	W	4,597	7	No	89.5%	Yes	1	0.9	4,729	0	\$562	\$3,884	\$400	6.2
Roof	Cafeteria unit 2	1	Supply Fan	3.0	86.5%	No	W	4,597	7	No	89.5%	Yes	1	0.9	4,729	0	\$562	\$3,884	\$400	6.2
Roof	Band room	1	Supply Fan	2.0	84.0%	No	W	4,597	7	No	86.5%	Yes	1	0.6	3,221	0	\$383	\$3,261	\$200	8.0
Roof	Medium EF	17	Exhaust Fan	0.3	65.0%	No	W	2,745		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Large EF	4	Exhaust Fan	0.5	75.0%	No	W	2,745		No	75.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Small EF	7	Exhaust Fan	0.3	60.0%	No	W	2,745		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 8(UV unit)	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 30 (UV unit+Portable AC)	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 31	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 32	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 33	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 34	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 35	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0

		Existing Conditions							Proposed Conditions				Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 36	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 37	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 38	Unit Ventilator	2	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 3	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 5	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 6	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 8	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 7	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 29	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 28	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 27	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Faculty break room	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 25	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classroom 24	Unit Ventilator	1	Supply Fan	0.3	60.0%	No	W	2,873		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	Original portion of bldg.	1	Heating Hot Water Pump	5.0	89.5%	No	N	4,118	8	No	89.5%	Yes	1	0.5	6,435	0	\$764	\$17,180	\$1,800	20.1
Boiler Room	Original portion of bldg.	1	Heating Hot Water Pump	5.0	89.5%	No	N	915	8	No	89.5%	Yes	1	0.5	1,430	0	\$170	\$17,180	\$1,800	90.5
Boiler Room	Boilers	2	Combustion Air Fan	2.0	84.0%	No	W	2,745		No	84.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	Areas other than orig. bldg.	1	Heating Hot Water Pump	5.0	89.5%	No	W	4,118	8	No	89.5%	Yes	1	0.5	6,435	0	\$764	\$17,180	\$1,800	20.1
Boiler Room	Areas other than orig. bldg.	1	Heating Hot Water Pump	5.0	89.5%	No	W	915	8	No	89.5%	Yes	1	0.5	1,430	0	\$170	\$17,180	\$1,800	90.5
Gymnasium	Gymnasium	1	Supply Fan	15.0	87.5%	No	W	2,873	7	No	93.0%	Yes	1	4.7	15,245	0	\$1,811	\$7,041	\$2,400	2.6

		Existing Conditions							Proposed Conditions				Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	DHW System	1	DHW Circulation Pump	0.2	60.0%	No	W	8,760		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	Kitchen Hood	1	Kitchen Hood Exhaust Fan	1.0	82.5%	No	W	1,540	9	No	85.5%	Yes	1	0.0	2,688	78	\$1,110	\$3,010	\$150	2.6
Indoors	Room 11 & 12	1	Supply Fan	0.2	60.0%	No	W	1,592		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Indoors	Nurse's Office	1	Supply Fan	0.2	60.0%	No	W	1,592		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Indoors	Conference Room	1	Supply Fan	0.2	60.0%	No	W	1,592		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Indoors	Media center unit 1	1	Supply Fan	0.2	60.0%	No	W	1,592		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Indoors	Media center unit 2	1	Supply Fan	0.2	60.0%	No	W	1,592		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Office	1	Ductless Mini-Split AC	1.00		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	Room 11 & 12	1	Split-System AC	1.50		B	10	Yes	1	Split-System AC	1.50		15.00		0.1	117	0	\$14	\$2,244	\$276	141.1
Roof	Nurse's Office	1	Split-System AC	5.00		B	10	Yes	1	Split-System AC	5.00		15.00		0.5	391	0	\$47	\$7,481	\$920	141.1
Roof	Conference Room	1	Split-System AC	1.50		B	10	Yes	1	Split-System AC	1.50		15.00		0.2	120	0	\$14	\$2,244	\$276	137.7
Roof	Computer room for students	1	Packaged AC	5.00		B	10	Yes	1	Packaged AC	5.00		15.00		1.0	802	0	\$95	\$11,345	\$920	109.4
Roof	Media center unit 1	1	Split-System AC	10.60		B	10	Yes	1	Split-System AC	10.60		12.50		2.8	2,245	0	\$267	\$12,336	\$1,548	40.4
Roof	Media center unit 2	1	Split-System AC	5.00		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	Cafeteria unit 1	1	Packaged AC	12.50		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	Cafeteria unit 2	1	Packaged AC	15.00		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	Band room	1	Packaged AC	5.00		B	10	Yes	1	Packaged AC	5.00		15.00		1.0	802	0	\$95	\$11,345	\$920	109.4
Roof	MDF room	1	Ductless Mini-Split HP	0.75	12.00	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Main Office	Main office open area PTHPs	3	Through-The-Wall HP	1.00	10.73	B		No							0.0	0	0	\$0	\$0	\$0	0.0
Main Office	Main office open area PTHPs	3	Electric Resistance Heat		13.65	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Outside	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Outside	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Outside	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 7	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 30 (UV unit+Portable AC)	Portable AC unit	1	Window AC	0.75		W	10	Yes	1	Window AC	0.75		12.10		0.2	164	0	\$20	\$817	\$0	41.8
Classroom 31	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 34	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0

		Existing Conditions					Proposed Conditions								Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 35	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 36	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 6	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 8	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 41	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 42	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 14	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 15	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 18	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 19	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 27	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Faculty break room	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 24	Window AC	1	Window AC	0.67		W		No							0.0	0	0	\$0	\$0	\$0	0.0

Fuel Heating Inventory & Recommendations

		Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Output Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units		Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	HHW system	1	Non-Condensing Hot Water Boiler	3,098	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	HHW system	1	Non-Condensing Hot Water Boiler	3,098	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium	Gymnasium	1	Furnace	1,500	B	11	Yes	1	Furnace	1,500	95.00%	AFUE		0.0	0	115	\$1,167	\$33,986	\$800	28.4

Demand Control Ventilation Recommendations

		Recommendation Inputs					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Affected	ECM #	Number of Zones	Cooling Capacity of Controlled System (Tons)	Electric Heating Capacity of Controlled System (kBtu/hr)	Output Heating Capacity of Controlled System (MBh)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Cafeteria	Cafeteria	12	2.00	27.50	0.00	350.00	0.0	603	14	\$217	\$2,719	\$0	12.6
Gymnasium	Gymnasium	12	2.00	0.00	0.00	1,500.00	0.0	0	79	\$796	\$2,719	\$0	3.4

DHW Inventory & Recommendations

		Existing Conditions			Proposed Conditions							Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	DHW system	1	Storage Tank Water Heater (> 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0

Low-Flow Device Recommendations

		Recommendation Inputs				Energy Impact & Financial Analysis						
Location	ECM #	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Classrooms	13	27	Faucet Aerator (Kitchen)	2.50	1.50	0.0	0	8	\$76	\$194	\$108	1.1
Kitchen/Break room	13	9	Faucet Aerator (Kitchen)	2.50	1.50	0.0	0	3	\$25	\$65	\$36	1.1
Restrooms	13	12	Faucet Aerator (Lavatory)	2.50	0.50	0.0	0	7	\$68	\$86	\$86	0.0

Commercial Refrigerator/Freezer Inventory & Recommendations

Existing Conditions				Proposed Conditions		Energy Impact & Financial Analysis						
Location	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Stand-Up Refrigerator, Solid Door (>50 cu. ft.)	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Stand-Up Freezer, Solid Door (>50 cu. ft.)	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Refrigerator Chest	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Freezer Chest	No	14	Yes	0.4	3,201	0	\$380	\$1,950	\$0	5.1

Cooking Equipment Inventory & Recommendations

Existing Conditions				Proposed Conditions		Energy Impact & Financial Analysis						
Location	Quantity	Equipment Type	High Efficiency Equipment?	ECM #	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Electric Steamer	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	2	Electric Combination Oven/Steam Cooker (15 - 28 Pans)	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	2	Gas Convection Oven (Full Size)	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Gas Convection Oven (Half Size)	No		No	0.0	0	0	\$0	\$0	\$0	0.0

Dishwasher Inventory & Recommendations

Existing Conditions						Proposed Conditions		Energy Impact & Financial Analysis					
Location	Quantity	Dishwasher Type	Water Heater Fuel Type	Booster Heater Fuel Type	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Payback w/ Incentives in Years
Kitchen	1	Single Tank Conveyor (High Temp)	Natural Gas	Electric	No		No	0.0	0	0	\$0	\$0	0.0

Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified ?
Classrooms	7	Ceiling Fan	100	
Classrooms/Faculty Break Room	18	Desk Fan	75	
Classrooms/Computer Lab/Main Office/Media Center/IT Room/Nurse's office/Copy Room	60	Desktop Computer	33	
Classrooms	18	Projector	200	
Classrooms	1	Television	120	
Classrooms	7	Printer (Small/Medium)	50	
Main Office/Nurse's office	5	Microwave Oven	1,200	
IT Equipment Room/Classrooms/Media Center	75	Laptop Computer	17	
Copy Rooms	5	Large Printer	550	
Faculty Break Room/Main office/Nurse's office	3	Refrigerator	600	
Copy Rooms	2	Paper Shredder	360	
Main office	1	Toaster oven	1,200	
Nurse's office/Faculty Break Room	2	Water Cooler	500	
Main Office	1	Mini Fridge	100	

Vending Machine Inventory & Recommendations

Custom (High Level) Measure Analysis

Installation of an Energy Management System


Building Square Footage 25,710
Percent of Conditioned Area Impacted 100%

Fuel Utility Rate \$10.111 MMBtu
Blended Electric Utility Rate \$0.119 kWh


Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis							
Description	Area(s)/System(s) Served	Remaining Useful Life	Total HVAC Motor Usage kWh	Total HVAC Electric Usage kWh	Total HVAC Fuel Usage MMBtu	Description	% Savings HVAC Motor Usage kWh	% Savings HVAC Electric Usage kWh	% Savings HVAC Fuel Usage MMBtu	Estimated Cost per Sqft	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Limited/No HVAC Controls	HVAC Equipment & Systems		191,707	51,050	4,115	Installation of an Energy Management System	3%	2%	5%	\$3.50	0.00	6,772	206	\$2,885	\$89,985	\$0	31.19

APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE

EUI is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.



ENERGY STAR® Statement of Energy Performance



**ENERGY STAR®
Score¹**

Conover Road Elementary School

Primary Property Type: K-12 School
Gross Floor Area (ft²): 85,689
Built: 1967

For Year Ending: September 30, 2019
Date Generated: August 25, 2020

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information			
Property Address Conover Road Elementary School 76 Conover Road Colts Neck, New Jersey 07722	Property Owner Colts Neck Township Board of Education 70 Conover Road Colts Neck, NJ 07722 (732) 946-0055	Primary Contact Vincent Marasco 70 Conover Road Colts Neck, NJ 07722 (732) 946-0055 ext.4101 marasco@coltsneckschools.org	
Property ID: 10189305			

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI	Annual Energy by Fuel		National Median Comparison
72.9 kBtu/ft²	Natural Gas (kBtu)	4,365,126 (70%)	National Median Site EUI (kBtu/ft²) 60.1
	Electric - Grid (kBtu)	1,877,377 (30%)	National Median Source EUI (kBtu/ft²) 94.8
			% Diff from National Median Source EUI 21%
Source EUI			Annual Emissions
114.8 kBtu/ft²			Greenhouse Gas Emissions (Metric Tons CO2e/year) 412

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: _____ Date: _____

Licensed Professional

() - _____



Professional Engineer or Registered
Architect Stamp
(if applicable)

APPENDIX C: GLOSSARY

TERM	DEFINITION
Blended Rate	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
Btu	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
CHP	<i>Combined heat and power</i> . Also referred to as cogeneration.
COP	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
Demand Response	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
DCV	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
US DOE	<i>United States Department of Energy</i>
EC Motor	<i>Electronically commutated motor</i>
ECM	<i>Energy conservation measure</i>
EER	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
EUI	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
Energy Efficiency	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
ENERGY STAR®	ENERGY STAR® is the government-backed symbol for energy efficiency. The ENERGY STAR® program is managed by the EPA.
EPA	<i>United States Environmental Protection Agency</i>
Generation	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
GHG	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
gpf	<i>Gallons per flush</i>

gpm	<i>Gallon per minute</i>
HID	<i>High intensity discharge:</i> high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.
hp	<i>Horsepower</i>
HPS	<i>High-pressure sodium:</i> a type of HID lamp
HSPF	<i>Heating seasonal performance factor:</i> a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.
HVAC	<i>Heating, ventilating, and air conditioning</i>
IHP 2014	US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.
IPLV	<i>Integrated part load value:</i> a measure of the part load efficiency usually applied to chillers.
kBtu	One thousand British thermal units
kW	<i>Kilowatt:</i> equal to 1,000 Watts.
kWh	<i>Kilowatt-hour:</i> 1,000 Watts of power expended over one hour.
LED	<i>Light emitting diode:</i> a high-efficiency source of light with a long lamp life.
LGEA	<i>Local Government Energy Audit</i>
Load	The total power a building or system is using at any given time.
Measure	A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.
MH	<i>Metal halide:</i> a type of HID lamp
MBh	<i>Thousand Btu per hour</i>
MBtu	<i>One thousand British thermal units</i>
MMBtu	<i>One million British thermal units</i>
MV	<i>Mercury Vapor:</i> a type of HID lamp
NJBPU	<i>New Jersey Board of Public Utilities</i>
NJCEP	<i>New Jersey's Clean Energy Program:</i> NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money and the environment.
psig	<i>Pounds per square inch gauge</i>
Plug Load	Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.
PV	<i>Photovoltaic:</i> refers to an electronic device capable of converting incident light directly into electricity (direct current).

SEER	<i>Seasonal energy efficiency ratio:</i> a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
SEP	<i>Statement of energy performance:</i> a summary document from the ENERGY STAR® Portfolio Manager®.
Simple Payback	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
SREC	<i>Solar renewable energy credit:</i> a credit you can earn from the state for energy produced from a photovoltaic array.
TREC	<i>Transition Incentive Renewable Energy Certificate:</i> a factorized renewable energy certificate you can earn from the state for energy produced from a photovoltaic array.
T5, T8, T12	A reference to a linear lamp diameter. The number represents increments of 1/8 th of an inch.
Temperature Setpoint	The temperature at which a temperature regulating device (thermostat, for example) has been set.
therm	100,000 Btu. Typically used as a measure of natural gas consumption.
tons	A unit of cooling capacity equal to 12,000 Btu/hr.
Turnkey	Provision of a complete product or service that is ready for immediate use
VAV	<i>Variable air volume</i>
VFD	<i>Variable frequency drive:</i> a controller used to vary the speed of an electric motor.
WaterSense®	The symbol for water efficiency. The WaterSense® program is managed by the EPA.
Watt (W)	Unit of power commonly used to measure electricity use.